

---

**BARRY GLASSMAN**  
HARFORD COUNTY EXECUTIVE

**BILLY BONIFACE**  
DIRECTOR OF ADMINISTRATION



**PAUL E. LAWDER**  
DIRECTOR OF INSPECTIONS,  
LICENSES AND PERMITS

---

**Harford County HVACR Mechanical Board  
Open Session  
October 12, 2016**

---

The Harford County HVACR Mechanical Board met in the 1<sup>st</sup> floor conference room, Department of Inspections, Licenses, and Permits, at 220 South Main Street on Wednesday, October 12, 2016. The following members were present:

**Members:**

Richard Foard, Chairman  
Kenny Blevins, Vice Chairperson  
Roger Welsh  
Terry Artman  
Craig Robey  
Heather McHugh, Secretary to the Board  
Scott Schott, Chief, Plumbing Services  
Milford Badders- Guest, Chief, Electrical Services

The meeting opened at 9:30 am. The Mechanical Board minutes recorded on October 12, 2016 were reviewed and approved.

**Old Business**

The Harford County HVACR Mechanical Board (also known as The Board) was updated on the current business practices by One Hour Heating and Air.

**New Business**

The Board discussed aluminum and copper wire whips for A/C and heat pump units. The Harford County Electrical Board will be approached by Milford Badders to entertain the idea of developing a training program for mechanical contractors to test for a limited electrical license.

The Board reviewed the plastic pan submitted by Krause Construction Company. The Board determined the pan is code compliant.

The Board discussed condensate drains and emergency shutoffs on replacement and newly installed units. The Board determined the pan and water switch replacement shall be enforced according to section m1411.3 through m1411.5 from the 2015 IRC.

*MARYLAND'S NEW CENTER OF OPPORTUNITY*

410.638.3344 | 410.879.2000 | TTY Maryland Relay 711 | [www.harfordcountymd.gov](http://www.harfordcountymd.gov)

220 South Main Street, Bel Air, Maryland 21014

THIS DOCUMENT IS AVAILABLE IN ALTERNATIVE FORMAT UPON REQUEST

There being no further business, the meeting was adjourned at 10:10 am.

Transcribed by and date:

*Heather McHugh*  
Heather McHugh 10/14/16  
Secretary to the Board

Reviewed by and date:

*Scott Schott*  
Scott Schott 10/14/16  
Chief, Plumbing Services


5 4 3 2 1

SCOTT CAN YOU CALL ME -

R.E. MICHELIS SAID NOT STAMPED ON PART. BUT I THINK THIS IS OK ?

LARRY KRAUSE 443-829-3519

1.4 mm 0.0625 inch



[812mm] 32.0in



[813mm] 32.0in



[53mm] 2.1in

NOTES:

- Extreme Temperature Durability (-40°F to 260°F).
- High Tensile Strength.
- Crack/Split/Leak/Rust Resistant.
- Self Extinguishing.
- DexElar Material is UL-94 5VA
- Made With Pride in the USA

ENGINEERING	NAME	DATE
DRAWN BY ENG.	DS	10/13/09
CHECKED BY ENG.	JK	10/13/09
ENG APPR.	CC	10/13/09
MFG APPR.	CC	10/13/09

PROPRIETARY AND CONFIDENTIAL

THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF RESOURCE CONSERVATION TECHNOLOGIES. NO REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF RESOURCE CONSERVATION TECHNOLOGIES IS PROHIBITED.

UNLESS OTHERWISE SPECIFIED:

DIMENSIONS ARE IN INCHES  
TOLERANCES:  
FRACTIONS ±.032  
DECIMALS ±.015  
ANGULAR ±.01  
TWO PLACE DECIMAL ±.010  
THREE PLACE DECIMAL ±.005  
INTERPRET GEOMETRIC TOLERANCING PER: ANSI Y14.5, 1994

**RESOURCE**  
CONSERVATION TECHNOLOGIES  
64208 PARKLAND DRIVE SUITE 102  
SARASOTA, FL 34243 888-708-6622

TITLE:

AG-T 32x32 SPECIFICATION SHEET

SIZE **A**

SCALE: 1:10

SHEET 1 OF 1

5 4 3 2 1