

---

**BARRY GLASSMAN**  
HARFORD COUNTY EXECUTIVE

**BILLY BONIFACE**  
DIRECTOR OF ADMINISTRATION



**PAUL E. LAWDER**  
DIRECTOR OF INSPECTIONS,  
LICENSES AND PERMITS

---

**Harford County Plumbing Board  
Open Session  
December 6, 2016**

---

The Harford County Plumbing Board met in the 1<sup>st</sup> floor conference room, Department of Inspections, Licenses, and Permits, at 220 South Main Street on Tuesday, December 6, 2016. The following members were present:

**Members:**

Steve Bogan, Vice Chairperson  
Scott Schott, Chief, Plumbing Services  
Brian Hendrix, Master Plumber  
Lisa Kalama, Environmental Health  
Heather McHugh, Secretary to the Board

The Plumbing Board minutes on December 6, 2016 were reviewed and approved.

**Old Business**

The Harford County Plumbing Board (also known as, the Board) discussed chemical dispenser system connections. The Board decided the installation of a ASSE.1024 dual check valve must be used to connect a chemical dispenser to the riser of a three compartment sink faucet to protect from a cross connection between hot and cold water.

The ECOLAB Quik Fill Side Kick Plumbing accessory is an acceptable connection from a mop sink to a chemical dispenser. The Quik Fill Side Kick must be installed per the manufactures specifications.

**New Business**

The Harford County Plumbing Board discussed the use of light duty commercial water heaters in a residential property. All residential water heaters must be NAECA III approved. Commercial water heaters are not NAECA III approved and cannot be used in Harford County residential properties.

The Board discussed the Phase II features of the Harford County ePermit Center.

There being no further business, the meeting was adjourned at 10:35 am.

*MARYLAND'S NEW CENTER OF OPPORTUNITY*

410.638.3344 | 410.879.2000 | TTY Maryland Relay 711 | [www.harfordcountymd.gov](http://www.harfordcountymd.gov)

220 South Main Street, Bel Air, Maryland 21014

THIS DOCUMENT IS AVAILABLE IN ALTERNATIVE FORMAT UPON REQUEST

Transcribed by and date:

*Heather McHugh*  
12/8/16

Heather McHugh  
Secretary to the Board

Reviewed by and date:

*Scott Schott*




Scott Schott 12/8/16  
Chief, Plumbing Services

# QUIK FILL SIDE KICK PLUMBING ACCESSORY KIT

The Side Kick is designed to be used where Quik Fill or Quik Fill Compac is installed on a faucet supplied with hot and cold water and equipped with an atmospheric vacuum breaker. This faucet type, with 3/4 inch hose threads, is found in typical custodial closets. The Side Kick provides a constant stream of 1/2 gal. of water per minute, whenever the faucet is turned on. This eliminates the problems associated with a downstream valve on this type of faucet. The Side Kick reminds the user to shut off the faucet after every use. Hot/cold cross connections cannot occur and the atmospheric vacuum breaker (AVB) is not under continuous line pressure. With this system the AVB is properly used and can provide backflow protection for the Quik Fill System.

1. To install the Side Kick, remove any "Y" connector that may be attached to the faucet.
2. Attach the female quick connect to the faucet. (Fig. 1)
3. Attach female end of the supply hose to the male thread on the Side Kick. (Fig. 2)
4. The Quik Fill system is now ready to operate. If a water supply hose is desired for other uses, attach it using a male quick connect.

Maximum Pressure: 80 PSI  
Maximum Temperature: 180° F



370 Wabasha Street N. St. Paul, MN 55102  
www.ecolab.com

© 2014 Ecolab Inc. All rights reserved.  
24823/8902/1114  
Part No. 9201-8498

**ECOLAB**®