

## Sanitary Sewer Overflows (SSOs) Reporting – 2016

Overall we experienced 12 recordable Sanitary Sewer Overflows (SSO's) during calendar year 2016. This equates to 1.51 SSO events per hundred miles of sewer. This performance is considered by most to be superior when compared to the national average of 4.5 SSO's per 100 miles as reported within a study done by the American Society of Civil Engineers.

Signs will be posted in areas where overflows have occurred. You are advised to avoid contact with the water and refrain from activities which may result in contact with the water. In the case of larger overflows that have the potential to impact human health or the environment, additional public notifications will be made as appropriate.

Please let us know if you have a concern with the sewer (odors and visible leaks). Call our service line at 410-612-1612, available to you 24 hours a day.

Date	Location	Quantity in Gallons (Estimated)	Cause
2/2/2016	2131 Old Edgewood Road, Edgewood, 21040	3,000	Obstruction of sewer by accumulation of rags and roots
2/2/2016	306 Rosecrest Court, Joppatowne, 21085	800	Obstruction of sewer by accumulation of rags and roots
2/28/2016	1203 Basil Court, Bel Air, 21015	1,300	Obstruction of sewer by accumulation of rags
2/28/2016	3044 Sounding Drive, Edgewood, 21040	1,200	Obstruction of sewer by accumulation of rags and roots
3/15/2016	10 South Bel Air Parkway, Abingdon, 21009	225	Obstruction of sewer by accumulation of rags and roots
3/24/2016	1875 Brookside Drive, Edgewood, 21085	200	Obstruction of sewer by accumulation of rags and roots
5/25/2016	4867 Atlas Cedar Drive, Aberdeen, 21001	1,800	Obstruction of sewer by accumulation of rags and roots
6/22/2016	5 Carroll Avenue, Edgewood, 21040	200	Obstruction of sewer by accumulation of debris
6/25/2016	Colgate Drive, near Kleins Plaza Drive, Forest Hill, 21050	400	Obstruction of sewer by accumulation of rags and roots
7/10/2016	512 South Tollgate Road, Bel Air, 21014	500	Obstruction of sewer by accumulation of debris
8/23/2016	MD Route 22 @ Bynum Run, Bel Air, 21014	1,800	Obstruction of sewer by accumulation of rags and debris
12/7/2016	Brentwood Park Pump Station, 1021 Red Pump Road, Bel Air, 21014	25,000	Structural failure of pressurized sewer discharge pipe
<b>Total for 2016</b>		<b>36,425</b>	

