

Sanitary Sewer Overflows (SSOs) Reporting – 2018

There were (7) Sanitary Sewer Overflows¹ (SSO's) during calendar year 2018. This equates to 0.89 SSO events per 100 miles of sewer; a slight increase in events compared to calendar year 2017 at 0.76 SSO's per 100 miles of sewer. This performance is considered, to be exceptional when compared to the national average of 4.5 SSO's per 100 miles of sewer².

Notifications will be posted in areas where overflows have occurred. You are advised to avoid contact with the water and refrain from activities which may result in contact with the water. In the case of larger overflows that have the potential to impact human health or the environment, additional public notifications will be made as appropriate.

Please let us know if you have a concern with the sewer (odors and visible leaks). Call our maintenance service line at 410-612-1612, available to you 24 hours a day.

Date	Location	Quantity in Gallons (Estimated)	Cause
2/5/18	516 East Wheel Road, Bel Air	300	Rags
2/28/18	Route 22 at Sablewood Drive, Bel Air	500	Grease
3/12/18	Sod Run WWTP, Perryman (Digester)	3000	Mechanical/Electrical Failure
3/16/18	1709 Edgewood Road, Edgewood	840	Grease and Rags
7/5/18	4302 Marigold Lane, Belcamp	1,275	Grease and Wipes
7/23/18	Haverhill SPS, 113 Haverhill Rd., Joppa	200	Heavy Precipitation & Mechanical/Electrical Failure
10/23/18	2206 Pulaski Highway, Havre de Grace	646	Mechanical Failure (service valve on privately owned grinder pump)
		6,761	TOTAL for 2018

1. Per Code of Maryland Regulations *COMAR 26.08.10*

2. As reported by a study done by the American Society of Civil Engineers.

